

Amy Ow

From: Jessica Henderson-McBean <JHenderson-McBean@swca.com>
Sent: Friday, October 9, 2020 2:55 PM
To: robertpellegrine@yahoo.com
Cc: Bob Pellegrine; Noel Chamberlain; Camille Leung; Amy Ow; Kristen Outten
Subject: Highland Estates Site Visit - 10/9/2020

CAUTION: This email originated from outside of San Mateo County. Unless you recognize the sender's email address and know the content is safe, do not click links, open attachments or reply.

Hello Bob,

It was nice to see you onsite today, and discuss the site condition together. Overall things are looking really good out there, and I appreciate that you addressed my action items from last visit. As we discussed, I will be onsite weekly from now on, as we are now in the wet season.

Please address the following action items that we identified together today:

Lots 9/10

- Please remove the staged lumber from the sidewalk on Cobblehill Place. We need to keep all construction materials within the approved work area.
- Please install the drain inlet protection that Neil had previously discussed with you. Now that we are in the wet season, drain inlet protection is required by the SWPPP.

Lot 11

- Please key in the silt fence on the southeast side of Lot 11. Thank you for installing new silt fence in this area, however it does need to be keyed in along the bottom per the requirements of the SWPPP.

Please let me know if you have any questions, and I will see you onsite next week!

Thanks,

Jessie Henderson-McBean
Project Manager / Biologist

SWCA Environmental Consultants
60 Stone Pine Road, Suite 100
Half Moon Bay, CA 94019
P 650.440.4160 x 6410 | C 805.712.8794



Visit Our New [Website!](#)

The contents of this email and any associated emails, information, and attachments are CONFIDENTIAL. Use or disclosure without sender's authorization is prohibited. If you are not an authorized recipient, please notify the sender and then immediately delete the email and any attachments.

